



Follow Like Share

SEARCH

## NARRAGANSETT RADIOLOGY

360 Kingstown Road, Suite 105  
Narragansett, RI 02882  
401-782-8808

✓ = Yes   ✗ = No   N/A = Not Applicable

### ACCESSIBILITY INFORMATION

#### Building Accessibility

##### ACCESSIBLE PARKING

Car – ✓Yes

Van – ✓Yes

##### ROUTE TO MAIN ENTRANCE FROM PARKING

Curb cuts available – ✓Yes

Clear path with no obstacles – ✓Yes

Route of travel (level or sloped) – Level

Route of travel 36" minimum width – ✓Yes

Ramp – N/A

Handrails 48" maximum height from ground – N/A

Automatic door entry – ✓Yes

Threshold at entry is flat or 1/2" maximum – ✓Yes

Doorway 32" minimum width – ✓Yes

##### ELEVATOR ACCESSIBILITY

Mammography Suite on main floor – ✓Yes

#### Mammography Suite Accessibility

**WAITING ROOM ACCESSIBILITY**

Entrance door 32" minimum width – ✓Yes

Floor space in seating area for wheelchair – ✓Yes

**CHANGING AREA**

Dressing room – ✗No

Changing area available in Mammography room – ✓Yes

**MAMMOGRAPHY ROOM**

Doorway 32" minimum width – ✓Yes

36" clear pathway to mammography machine – ✓Yes

60" turnaround for wheelchair – ✗No

Imaging plate lowers to 24" above the floor allowing a person to remain seated in wheelchair – ✓Yes

**RESTROOM ACCESSIBILITY**

Door 32" minimum width – ✓Yes

Push door or door handles are latch type – ✓Yes

Turnaround 60" minimum in toilet area – ✓Yes

Two grab bars 36" maximum height from floor – ✗No

Toilet paper dispenser 19" maximum height from floor – ✓Yes

Hand towel dispenser 48" maximum height from floor – ✓Yes

Sink has 29" minimum space from floor to base – ✓Yes

Sink faucet is lever operated, push, or electronically controlled – ✓Yes

Exposed pipes under the sink are wrapped – ✗No

Comment for Restroom: One horizontal grab bar in restroom.