

## XRA MEDICAL IMAGING

1524 Atwood Avenue  
 Johnston, RI 02919  
 401-351-1570

✓ = Yes    ✗ = No    N/A = Not Applicable

### ACCESSIBILITY INFORMATION

#### Building Accessibility

##### ACCESSIBLE PARKING

Car – ✓Yes

Van – ✗No

##### ROUTE TO MAIN ENTRANCE FROM PARKING

Curb cuts available – N/A

Clear path with no obstacles – ✓Yes

Route of travel (level or sloped) – Level

Route of travel 36" minimum width – ✓Yes

Ramp – N/A

Handrails 48" maximum height from ground – N/A

Automatic door entry – ✓Yes

Threshold at entry is flat or 1/2" maximum – ✓Yes

Doorway 32" minimum width – ✓Yes

Comment for Route to Main Entrance from Parking: Level path from parking area to curb free access at main entrance.  
 Automatic door entry main entrance, but double doors at second inner entrance not automatic.

##### ELEVATOR ACCESSIBILITY

Mammography Suite on main floor – ✓Yes

## ➔ Mammography Suite Accessibility

### WAITING ROOM ACCESSIBILITY

Entrance door 32" minimum width – ✓Yes

Floor space in seating area for wheelchair – ✓Yes

### CHANGING AREA

Dressing room – ✓Yes

Doorway 32" minimum width – ✓Yes

60" turnaround for wheelchair – ✗No

Changing bench – ✗No

Back support to bench – ✗No

Grab bars at bench area – ✗No

*Changing area available in Mammography room – ✓Yes*

Comment for Dressing Room: No bench, chair with back.

### 🗺️ MAMMOGRAPHY ROOM

Doorway 32" minimum width – ✓Yes

36" clear pathway to mammography machine – ✓Yes

60" turnaround for wheelchair – ✗No

Imaging plate lowers to 24" above the floor allowing a person to remain seated in wheelchair – ✓Yes

### 🚻 RESTROOM ACCESSIBILITY

Door 32" minimum width – ✓Yes

Push door or door handles are latch type – ✓Yes

Turnaround 60" minimum in toilet area – ✓Yes

Two grab bars 36" maximum height from floor – ✗No

Toilet paper dispenser 19" maximum height from floor – ✓Yes

Hand towel dispenser 48" maximum height from floor – ✓Yes

Sink has 29" minimum space from floor to base – ✓Yes

Sink faucet is lever operated, push, or electronically controlled – ✓Yes

Exposed pipes under the sink are wrapped – ✓Yes

Comment for Restroom: One horizontal grab bar.